



**BRUHAT BENGALURU MAHANAGARA PALIKE**

**Office of the Medical Officer Of Health, Mahadevapura Zone, Bangalore - 560048**

**NO:-BBMP/MOH/MDP/PR/35/2023-24**

**DATE:28/06/2023**

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE**

It is certified that an inspection team headed by **Dr.Rakesh N, Medical Officer of Health** and **Nagaraju.V, Senior Health Inspector** (Name Of Officers with designation) from **BBMP Health Department** (Name of Department /Office) Inspected the **Riverstone International School, #33 & 34, Byrathi Village, Doddagubbi Post, Avalahalli Main Road, Bangalore-560077** (Name & Address of the school) on **28-06-2023** and checked the water test report submitted by the School and found that the School has Potable Drinking water for students and staff of the **Riverstone International School** Institution. And is having provision for running water in the toilets and is maintaining the hygienic sanitation condition in the School building & the campus as per the norms prescribed by the Central /state/U.T.Govt.

The Above NOC is Valid for the Period of Two Years from the date of Issue.

Signature with Seal:

Name

: **Dr.Rakesh N**

Designatin

: **Medical Officer of Health**

**BBMP Mahadevapura Zone.**

To,

**Riverstone International School,  
#33 & 34, Byrathi Village,  
Doddagubbi Post, Avalahalli Main Road,  
Bangalore-560077**

**(TRANSLATION OF KANNADA SEAL TO ENGLISH)**

SEAL

Medical Officer of Health  
Mahadevapura Zone  
BBMP

Annexure C

Appendix-XIII

**BRUHATH BANGALORE MAHANAGARA PALIKE**

**OFFICE OF THE MEDICAL OFFICER OF HEALTH, MAHADEVAPURA ZONE,  
BANGALORE - 560048**

No. BBMP/MOH/MDP/PR/35/2023-24

Date : 28.06.2023

**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE**

It is certified that an inspection team headed by **Dr. Rakesh N., Medical Officer of Health** and **Nagaraju V., Senior Health Inspector** (Name of Officers with Designation) from **BBMP Health Department** (Name of Department/Office) inspected the **RIVERSTONE INTERNATIONAL SCHOOL**, at **#33 & 34, Byrathi Village, Doddagubbi Post, Avalahalli Main Road, Bangalore 560077** (Name & Address of the School) on **28-06-2023** and checked the water test report submitted by the school and found that the school has Potable Drinking water for students and staff of the **Riverstone International School** Institution and is having provision for running water in the toilets and is maintaining hygienic sanitation condition in the School building & the campus as per the norms prescribed by the Central / State / U.T. Govt.

**The above NOC is Valid for a period of 2 years from the date of issue.**



Signature and Seal : Sd/-  
Name : Dr. Rakesh N.  
Designation : Medical Officer of Health  
Name and Address : BBMP,  
of the Office / Department : Mahadevapura Zone  
Bengaluru

To,  
**RIVERSTONE INTERNATIONAL SCHOOL,**  
**#33 & 34,**  
**Byrathi Village,**  
**Doddagubbi Post,**  
**Avalahalli Main Road,**  
**Bangalore 560077**



"ATTESTED BY ME"

*Ratna N.* 17/7/23  
**RATNA.N.**  
Bcom.,LL.B.,  
Advocate & Notary Public  
GOVT. OF INDIA  
No. 500/ B, Shree Complex, 8th Main, 4th Stage,  
Basaveshwaramagar, Bengaluru - 560 079  
Mob : 98801 96880





# INDIAN ANALYTICAL TESTING LABORATORY



An ISO 9001:2015 Certified Laboratory

No.3, 3<sup>rd</sup> Floor, A Main Road, North Layout, Nayandanahalli, Near Indian Oil Petrol Bunk, Bangalore: 560039, Karnataka.

Mob No: 7899440170 E-Mail: [iatlaboratory@gmail.com](mailto:iatlaboratory@gmail.com) Web site: [iatlabs.com](http://iatlabs.com)

## TEST CERTIFICATE

|  |  |
|--|--|
| Certificate No.: IATL023/01/SCW/003  | Certificate Date: 09/01/2023           |
| Issued To:<br><b>RIVERSTONE INTERNATIONAL SCHOOL</b><br>No 33/34, Avalahalli main road, Byrathi village,<br>Bangalore-560077 | Date of Receipt: 02/01/2023            |
|  | Sample Code.: IATL023/01/SCW/003       |
|  | Sample Collected By: IATLab            |
| Sample Description: Colorless, Transparent liquid  | Description of Sample : Drinking Water |

| Sl. No. | Parameters                                 | Test Method (Reference) | Limits AS per 10500:2012 | Results      |
|---------|--|-------------------------|--------------------------|--------------|
| 01      | Color, Hazen Units                         | IS 3025 (Part 4)        | 2 Unit                   | <1.0         |
| 02      | Odor                                       | IS 3025 (Part 5)        | Agreeable                | Agreeable    |
| 03      | Taste                                      | IS 3025 (Part 8)        | Agreeable                | Agreeable    |
| 04      | Turbidity, NTU                             | IS 3025 (Part 10)       | 1.0 NTU                  | 0.00         |
| 05      | pH @ 25 <sup>o</sup> C                     | IS 3025 (Part 11)       | 6.5 to 8.5               | 6.57         |
| 06      | Chloride as Cl, mg/L                       | IS 3025 (Part 32)       | 250.0                    | 4.00         |
| 07      | Sulphate as SO <sub>4</sub> , mg/L         | IS 3025 (Part 24)       | 200.0                    | <1.00        |
| 08      | Alkalinity as CaCO <sub>3</sub> , mg/L     | IS 3025 (Part 23)       | 200.0                    | 8.00         |
| 09      | Total Dissolved Solids, mg/L               | IS 3025 (Part 16)       | 500.0                    | 23.90        |
| 10      | Residual Free Chlorine, mg/L               | IS 3025 (Part 26)       | 0.2                      | BDL          |
| 11      | Total Hardness as CaCO <sub>3</sub> , mg/L | IS 3025 (Part 21)       | 200.0                    | 10.00        |
| 12      | Copper as Cu, mg/L                         | IS 3025 (Part 42)       | 0.05                     | <0.01        |
| 13      | Iron as Fe, mg/L                           | IS 3025 (Part 53)       | 0.10                     | <0.01        |
| 14      | Calcium as Ca, mg/L                        | IS 3025 (Part 40)       | 75.0                     | 2.40         |
| 15      | Magnesium as Mg, mg/L                      | IS 3025 (Part 46)       | 30.0                     | 0.97         |
| 16      | Nitrate as No <sub>3</sub> , mg/L          | IS 3025 (Part 34)       | 45.0                     | <1.00        |
| 17      | Aluminum as Al, mg/L                       | IS 3025 (Part 55)       | 0.03                     | <0.001       |
| 18      | Nitrite as NO <sub>2</sub> , mg/L          | IS 3025 (Part 34)       | 0.02                     | <0.001       |
| 19      | Fluoride as F, mg/L                        | IS 3025 /Part 60        | 1.0                      | <0.10        |
| 20      | Total Coliform, MPN/100 ml                 | IS:1622-1981            | Not Detectable           | Not Detected |
| 21      | E. coli, MPN/100 ml                        | IS: 1622-1981           | Not Detectable           | Not Detected |

BDL-Below Detection Limit

Report Status: The tested water sample meets to acceptable limit as per IS 10500: 2012 for above Physical, Chemical and Microbiological Testing.

\*\*\*\*\*End of the Report\*\*\*\*\*

Analysed by:



- Note: 1. The results listed pertain only to the tested samples and applicable parameters.  
2. Sample will be destroyed after 15 days from the date of issue of test certificate unless & otherwise specified.  
3. This report is not be reproduced either wholly or in part cannot be used an evidence in the court of law and should not be used In any advertising media without prior written permission.  
4. Sampling not done by us, unless specified.

GOVERNMENT OF KARNATAKA

No:PHI/Water/BAC/ 961/23-24

Office of the Joint Director  
Public Health Institute  
Bengaluru - 560 001

Dated: 19/02/2024

Report of Bacteriological analysis of Water/Effluent sample

| Sample No. | Source & Particulars of Water Sample   | Opinion     |             |          | S.P.P | N.S.P.P | N.S.P.P & FC. |
|------------|--|-------------|-------------|----------|-------|---------|---------------|
|            |  | M.P.N Count | Plate Count | D.C Test |       |         |               |
| 3047       | Principal River Stone<br>International School<br>No 33/34, Byjerathi<br>Village, Doddagubbi (PO)<br>Analakatti, MN. RD<br>Bongaluru - 560077<br>B.NO-4129940 | Nil         | -           | -        | SPP   | -       | -             |

Note:  
M.P.N Count:  
Most probable number of Bacteria per 100ml of Water  
D.C Test:  
Differential Coliform test  
Plate Count:  
Plate Count per ml of sample  
SPP:  
Water is satisfactory for Potable purpose  
NSPP:  
Water is not satisfactory for Drinking purpose  
NSPP & FC:  
Water is not satisfactory for Drinking purpose and E.Coli found

For Joint Director (Labs)  
PUBLIC HEALTH INSTITUTE  
Bengaluru

For Joint Director (Lab)  
Public Health Institute  
Bengaluru, K.R. Circle,  
- 560 001.

(PTO)